Replacement Parts List No. 700009400
Revision C 10/2013

Air Cooled Global Condensing Unit
Scroll Compressor

ACZ
Sizes: 010 - 039
Single Circuit
Vintage: A
R22 & R407C

McQuay International
a member of DAIKIN group

Contents

Parts List Revision History....3
Nomenclature
- Serial Number....4
- Unit Model Number- Dataplate....4
- Stock Unit: Model Number....4
- Unit Model Number- Complete....4, 5

Electrical Legend....6
Unit Layout....7
Refrigeration Section
- Compressors, Crankcase Heaters, Sound Reduction....8, 9
- Tubing- Liquid Line, Suction, Discharge, Hot Gas Bypass....10

Condenser Section
- Condenser Coil, Fan Deck Components....11
- Condenser Coils....12

Cabinet
- Coil Guards, Channels, Hardware....13
- Panels....14

Control Panel
- Main Control Box....15
- Misc. Controls- Transducers, Pressure Switches and Sensors....15

Field Installed Accessories
- Alarm Bell Kit....16
- Phase Voltage Monitor Kit....16
- Speedtrol Kit....16
- Refrigerant Specialties....16
- Isolators....17
- BACnet with IP/Ethernet....18
- BACnet Communications Module MS/TP....18
- MODBUS Communications Module....18
- LonMark Communications Module....18

Critical Parts List....CPL1, CPL2

Parts List Revision History

Revision	Date	Description
NEW	11/07	New
A	7/08	Added R22 & R407C to cover and footer. Page 10 - Bub #81 and #83 were reversed.
B	1/10	Page 11- Ref #1 change description from LH to RH. Ref #1A change description from RH to LH.
C	10/2013	Page 1: Revised cover title to include “Single Circuit”. Page 4: Revised Unit Model nomenclature Sizes to include “Single Circuit”. Page 17: Removed Spring Isolator part numbers, added note to contact Daikin Applied. Pages 19-20: Added CPL pages.

Nomenclature

Serial Number

STN U 03 05 048

Plant Identification
STN = Staunton, VA

U= Unit

Year of Manufacture
01= 2001
02= 2002
03= 2003
04= 2004
etc.

Month of Manufacture

01= January	07= July
02= February	08= August
03= March	09= September
04= April	10= October
05= May	11= November
06= June	12= December

Serial Number (build sequence)

Unit Model Number- Dataplate

ACZ 010 A C

Platform
C= Standard Condensing Unit

Vintage

Nominal Tonnage
ex. 010= 10 Tons

Unit Type:
ACZ= Air- Cooled Scroll Compressor Condensing Unit

Stock Unit: Model Number

ACZ 010 A C 27

Voltage
12= 208/230V
27 = 460V

Application
C= Fantrol, PB, No HG
T= Speedtrol, DS, HGBP

Vintage

Nominal Tonnage
ex. 010 = 10 Tons

Unit Type:
ACZ= Air- Cooled Scroll Compressor Condensing Unit

Unit Model Number- Complete

ACZ	010A	C	S	NN	N	S	NN	A	F	T	G	NN	M2SN	ENSS	27	AL	PN	N	N	N	NN	NN	NN	NN
Code	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25

NN	E	N	NN	NSUDPNNONCPE1NNNNNNND00	NNNN	S	00
26	27	28	29	30- 36	37, 38	39	40

02 Size (in nominal tons)
010A= 10 Tons 'A'Vintage, Single Circuit
013A= 13 Tons 'A'Vintage, Single Circuit
016A= 16 Tons 'A'Vintage, Single Circuit
020A= 20 Tons 'A'Vintage, Single Circuit
025A= 25 Tons 'A'Vintage, Single Circuit
028A= 28 Tons 'A'Vintage, Single Circuit
033A= 33 Tons 'A'Vintage, Single Circuit
039A= 39 Tons 'A'Vintage, Single Circuit

03 Platform
C= Standard Condensing Unit

04 Refrigerant
S= R22 7= R407C

05 Efficiency/Sound
NN= Standard Sound
WS= With Compressor Sound Reduction

06 Evaporator Insulation
N= None

07 Unit Operation
S= Standard Operation

08 Always NN

09 Condenser Coil Fins
A= Aluminum Fins
C= Copper Fins
B= Aluminum Fin w/ Prefab Blackfin Coating
E= Aluminum Fin w/Electrofin Coating
F= Copper Fin w/Electrofin Coating

10 Head Pressure
F= Fantrol (35° F Minimum)
S= Speedtrol (0° F Minimum)

11 Fan Motor
T= Totally Enclosed

Nomenclature
Continued

Unit Model Number- Complete, Continued

12 Condenser Coil Guards
G= Grilles
L= Louvers

13 Communication
NN= None LM= LonMark
MB= ModBus BN= BACnet w/MSTP
BE= BACnet w/Ethernet

14 Controls
M2SN= MicroTech

15 Sensor Options
ENSS= English, Standard Sensors

16 Voltage
12= 208/60/3 29= 230/60/3 27= 460/60/3
37= 575/60/3

17 Starter
AL= Across- the- Line

18 Power Connection
PN= Power Block
DN= Disconnect Switch
DH= High Short Circuit Current Relay w/DS

19 Phase Voltage
N= None
V= Phase & Under/Over Voltage Protection w/LED

20 Ground Fault
N= No Ground Fault Protection

21 Unit Options
N= No Unit Options

22 Always NN

23 Always NN

24 Tubing Options
NN= Standard
HG= Hot Gas Bypass

25 Unit Gauges
NN= No Gauges

26 Always NN

27 Approvals
E= ETL/CETL Approval
M= MEA & ETL/CETL Approval
A= No Approval

28 CRN- Evap
N= No CRN Required

29 Always NN

30- 36 Unit Start & Warranties

37, 38 Always NNNN

39 Unit- Misc.
S= Standard Unit
M= Stock Modification
X= Special

40 Revision
00= Latest Revision

Electrical Legend

Sch. Sym.	Description	Location
ABR	Alarm Bell Relay	Field Mounted
C11	Speedtrol Capacitor	Control Box
CHW1	Chilled Water Flow Switch	Field Mounted
CHWR	Chilled Water Relay	Field Mounted
COMPR 1, 2	Compressors	Below Control Box
C. BOX HEATER	Control Box Heater	Control Box
CONTROLLER	Unit Controller	Control Box
DS1	Disconnect Switch	Control Box
DXE1	DX Evaporator. Flow Switch	Field Mounted
DXER	DX Evaporator. Fan Relay	Field Mounted
F1	Control Circuit Fuse	Control Box
FB5	Control Power Fuses	Control Box
FB6	Speedtrol Transformer Fuses	Control Box
GRD	Ground	Control Box
HP1	High Pressure Switch	Discharge Line
HTR1, 2	Compressor Heaters	On Compressor
HTR5	Evaporator Heater	On Evaporator
IMS1	Ice Mode Switch	Field Mounted
M1, M2	Compressor Contactors	Control Box
M1, 2-AUX	Auxiliary Contacts	Control Box
M11-M13	Fan Contactors	Control Box
MJ	Mechanical Jumper	Control Box
MP1, MP2	Motor Protection	On Compressor
MS11-MS13	Fan Starters, Manual	Control Box
PB1	Power Block	Control Box
PVM	Phase Voltage Monitor	Control Box
S1	System Shut-Off Switch	Control Box
S00	Leaving Water Sensor	In Evaporator
S01	Suction Pressure Sensor	Suction Line
S03	Condensing Pressure Sensor	Discharge Line
S05	Outside Ambient Temperature Sensor	Behind Control Box
S06	Leaving Water Reset Sensor	Field Mounted
SC11	Speedtrol Controller	Control Box
SV1	Liquid Line Solenoid	Liquid Line
SV5	Hot Gas Bypass Solenoid	Hot Gas Bypass Line
T1	Control Transformer	Control Box
T2	24V Control Transformer	Control Box
T3	575V Control Transformer	Behind Control Box
TB1, TB2	Terminal Blocks	Control Box
TC2	Evaporator Thermostat	On Evaporator
WJ	Wire Jumper	Control Box

Unit Layout
(AGZ010BS shown)



Ref. No.	Description	Location
1	Compressor	Refrigeration Section
7	Hot Gas Bypass Valve	Refrigeration Section
8	Condenser Coils	Condenser Section
9	Fan Deck	Condenser Section
10	Control Box	Controls Section

Refrigeration Section
Compressors, Crankcase Heaters, Sound Reduction



Ref No.	Part Description	Part Number	Unit Size											
			010			013			016			020		
			208/230V	460V	575V	208/230V	460V	575V	208/230V	460V	575V	208/230V	460V	575V
	Tandem Compressor Assy R22 [1]													
1	Compressor #1,2 Tandem [3]	331343301	1											
	Compressor #1,2 Tandem [3]	331343302		1										
	Compressor #1,2 Tandem [3]	331343303			1									
	Compressor #1,2 Tandem [3]	074510101				1								
	Compressor #1,2 Tandem [3]	074510102					1							
	Compressor #1,2 Tandem [3]	074510103						1						
	Compressor #1,2 Tandem [3]	074510201							1					
	Compressor #1,2 Tandem [3]	074510202								1				
	Compressor #1,2 Tandem [3]	074510203									1			
	Compressor #1,2 Tandem [3]	074510301										1		
	Compressor #1,2 Tandem [3]	074510302											1	
	Compressor #1,2 Tandem [3]	074510303												1
	Tandem Compressor Assy R407C [2]													
1	Compressor #1,2 Tandem [3]	331507201	1											
	Compressor #1,2 Tandem [3]	331507202		1										
	Compressor #1,2 Tandem [3]	331507203			1									
	Compressor #1,2 Tandem [3]	331507301				1								
	Compressor #1,2 Tandem [3]	331507302					1							
	Compressor #1,2 Tandem [3]	331507303						1						
	Compressor #1,2 Tandem [3]	330662101							1					
	Compressor #1,2 Tandem [3]	330662102								1				
	Compressor #1,2 Tandem [3]	330662103									1			
	Compressor #1,2 Tandem [3]	330662201										1		
	Compressor #1,2 Tandem [3]	330662202											1	
	Compressor #1,2 Tandem [3]	330662203												1
1A	Crankcase Heater	074513201	2	2	2	2	2	2						
	Crankcase Heater	074513301							2	2	2	2	2	2
N/S	Sound Blanket- Compressor C05= WS	330388702							2	2	2	2	2	2

Refrigeration Section

Compressors, Crankcase Heaters, Sound Reduction, Continued



Ref No.	Part Description		Part Number	Unit Size											
				025			028			033			039		
				208/230V	460V	575V	208/230V	460V	575V	208/230V	460V	575V	208/230V	460V	575V
	Tandem Compressor Assy	**R22** [1]													
1	Compressor #1,2	Tandem [3]	074624001	1											
	Compressor #1,2	Tandem [3]	074624002		1										
	Compressor #1,2	Tandem [3]	074624003			1									
	Compressor #1,2	Tandem [3]	074549101				1								
	Compressor #1,2	Tandem [3]	074549102					1							
	Compressor #1,2	Tandem [3]	074549103						1						
	Compressor #1,2	Tandem [3]	074549201							1					
	Compressor #1,2	Tandem [3]	074549202								1				
	Compressor #1,2	Tandem [3]	074549203									1			
	Compressor #1,2	Tandem [3]	330388401										1		
	Compressor #1,2	Tandem [3]	330388402											1	
	Compressor #1,2	Tandem [3]	330388403												1
	Tandem Compressor Assy	**R407C** [2]													
1	Compressor #1,2	Tandem [3]	330663101	1											
	Compressor #1,2	Tandem [3]	330663102		1										
	Compressor #1,2	Tandem [3]	330663103			1									
	Compressor #1,2	Tandem [3]	330662401				1								
	Compressor #1,2	Tandem [3]	330662402					1							
	Compressor #1,2	Tandem [3]	330662403						1						
	Compressor #1,2	Tandem [3]	330662501							1					
	Compressor #1,2	Tandem [3]	330662502								1				
	Compressor #1,2	Tandem [3]	330662503									1			
	Compressor #1,2	Tandem [3]	330662601										1		
	Compressor #1,2	Tandem [3]	330662602											1	
	Compressor #1,2	Tandem [3]	330662603												1
1A	Crankcase Heater		074513301	2	2	2	2	2	2	2	2	2			
	Crankcase Heater		330388601										2	2	2
N/S	Sound Blanket- Compressor	C05= WS	330388702	2	2	2	2	2	2						
	Sound Blanket- Compressor	C05= WS	330388801							2	2	2			
	Sound Blanket- Compressor	C05= WS	330388901										2	2	2

N/S= Not Shown on Diagram.

[1] Code 04= S.

[2] Code 04= 7.

[3] Tandem compressor assembly includes two (2) compressors and the vibration mounting kit.

Refrigeration Section

Tubing- Liquid Line, Suction, Discharge, Hot Gas Bypass

Valves, Filter Drier, Sight Glass

Diagrams

Liquid Line Detail



Suction Line Detail



Discharge Line Detail



(Size 010 only)

Hot Gas Bypass Detail



Ref No.	Part Description		Part Number	Unit Size							
				010	013	016	020	025	028	033	039
	Suction Line										
51	Valve- Charge	.37 x .37	038689900	1	1	1	1	1	1	1	1
55	Valve Core		026541100	1	1	1	1	1	1	1	1
56	Valve Cap		032943500	1	1	1	1	1	1	1	1
68	Shrader Valve		071100801	1	1	1	1	1	1	1	1
	Discharge Valve										
55	Valve Core		026541100	3	3	2	2	2	2	2	2
56	Valve Cap		032943500	2	2	1	1	1	1	1	1
68	Shrader Valve		071100801	4	4	3	3	3	3	3	3
	Liquid Line										
15	Valve- Charge	.37 x .37	038689900	1	1	1	1	1	1	1	1
	Hot Gas Bypass										
81	Valve- Hot Gas Solenoid	.625" NC	024684104	1	1	1	1	1	1		
83	Valve- Pressure	.625"	070301706	1	1	1	1	1	1		
83A	Valve- Discharge Bypass	.875"	074696801							1	1

Condenser Section
Condenser Coil, Fan Deck Components



ACZ 010- 020 Shown

Ref No.	Part Description		Part Number	Unit Size					
				010, 013, 016, 020			025, 028, 033, 039		
				208/230V	460V	575V	208/230V	460V	575V
1	Condenser Coil	RH	[1]						
1A	Condenser Coil	LH	[1]						
2	Fan Panel	Front	330252001	1	1	1	1	1	1
2A	Fan Panel	Middle/Back	330251901	1	1	1	2	2	2
3	Grille	32.0"	330260301	2	2	2	3	3	3
4	Bracket- Fan Motor		330313901	4	4	4	6	6	6
6	Fan Motor- Standard	1HP TE	330287901	2 [2]	2 [2]		3 [3]	3 [3]	
	Fan Motor- Standard	1HP TE	074521101			2 [2]			3 [3]
6A	Fan Motor- Speedtrol [4]	1HP DP	350113901	1	1	1	1	1	1
8	Fan Prop	26"	330288001	2	2	2	3	3	3
10	Ground Wire Assy		350324101	2	2	2	3	3	3

[1] See Chart on the following page.
[2] If unit has Fantrol (Code 10= F) quantity is 2. If unit has Speedtrol (Code 10= S) quantity is 1.
[3] If unit has Fantrol (Code 10= F) quantity is 3. If unit has Speedtrol (Code 10= S) quantity is 2.
[4] Code 10= S. Speedtrol motor controls front fan.

Condenser Section
Condenser Coils

Ref No.	Part Description		Code 9=	Part Number	Unit Size			
					010-016	020	025,028	033,039
1	Condenser Coil- RH	Aluminum Fin	A	330255001	1			
	Condenser Coil- RH	Copper Fin	C	330255011	1			
	Condenser Coil- RH	Alum. w/ Blackfin Coat	B	330255021	1			
	Condenser Coil- RH	Alum. w/Electrofin Coat	E	330255001P	1			
	Condenser Coil- RH	Copp. w/Electrofin Coat	F	330255011P	1			
	Condenser Coil- RH	Aluminum Fin	A	330265001		1		
	Condenser Coil- RH	Copper Fin	C	330265011		1		
	Condenser Coil- RH	Alum. w/ Blackfin Coat	B	330265021		1		
	Condenser Coil- RH	Alum. w/Electrofin Coat	E	330265001P		1		
	Condenser Coil- RH	Copp. w/Electrofin Coat	F	330265011P		1		
	Condenser Coil- RH	Aluminum Fin	A	330254201			1	
	Condenser Coil- RH	Copper Fin	C	330254211			1	
	Condenser Coil- RH	Alum. w/ Blackfin Coat	B	330254221			1	
	Condenser Coil- RH	Alum. w/Electrofin Coat	E	330254201P			1	
	Condenser Coil- RH	Copp. w/Electrofin Coat	F	330254211P			1	
	Condenser Coil- RH	Aluminum Fin	A	330264201				1
	Condenser Coil- RH	Copper Fin	C	330264211				1
	Condenser Coil- RH	Alum. w/ Blackfin Coat	B	330264221				1
	Condenser Coil- RH	Alum. w/Electrofin Coat	E	330264201P				1
	Condenser Coil- RH	Copp. w/Electrofin Coat	F	330264211P				1
1A	Condenser Coil- LH	Aluminum Fin	A	330255101	1			
	Condenser Coil- LH	Copper Fin	C	330255111	1			
	Condenser Coil- LH	Alum. w/ Blackfin Coat	B	330255121	1			
	Condenser Coil- LH	Alum. w/Electrofin Coat	E	330255101P	1			
	Condenser Coil- LH	Copp. w/Electrofin Coat	F	330255111P	1			
	Condenser Coil- LH	Aluminum Fin	A	330265101		1		
	Condenser Coil- LH	Copper Fin	C	330265111		1		
	Condenser Coil- LH	Alum. w/ Blackfin Coat	B	330265121		1		
	Condenser Coil- LH	Alum. w/Electrofin Coat	E	330265101P		1		
	Condenser Coil- LH	Copp. w/Electrofin Coat	F	330265111P		1		
	Condenser Coil- LH	Aluminum Fin	A	330254301			1	
	Condenser Coil- LH	Copper Fin	C	330254311			1	
	Condenser Coil- LH	Alum. w/ Blackfin Coat	B	330254321			1	
	Condenser Coil- LH	Alum. w/Electrofin Coat	E	330254301P			1	
	Condenser Coil- LH	Copp. w/Electrofin Coat	F	330254311P			1	
	Condenser Coil- LH	Aluminum Fin	A	330264301				1
	Condenser Coil- LH	Copper Fin	C	330264311				1
	Condenser Coil- LH	Alum. w/ Blackfin Coat	B	330264321				1
	Condenser Coil- LH	Alum. w/Electrofin Coat	E	330264301P				1
	Condenser Coil- LH	Copp. w/Electrofin Coat	F	330264311P				1

Cabinet
Coil Guards, Channels, Hardware

Condenser Coil Grilles (Code 12= G)

ACZ 010- 020



ACZ 025- 039



Ref No.	Part Description	Part Number	Unit Size		
			010- 020	025, 028	033, 039
1	Grille 42"	330260401	2		
	Screw for 42" Grille	046093807	32		
	Grille 42"	330260501		4	
	Screw for 42" Grille	046093807		60	
	Grille 50"	330260601			4
	Screw for 42" Grille	046093807			68
2	Channel- 42" Grille	330267801		2	
	Channel- 50" Grille	330267901			2

Condenser Coil Louvers (Code 12= L)

ACZ 010- 020



ACZ 025- 039



Ref No.	Part Description	Part Number	Unit Size		
			010- 020	025, 028	033, 039
11	Louver 42" x 29"	330668301	2	6	
	Louver 50" x 29"	330668401			6
12	Louver 42" x 25"	330594001	2		
	Screw for Louvers	046093807	32	60	68

Cabinet
Panels



Ref No.	Part Description		Part Number	Unit Size	
				010, 013, 016 020, 025, 028	033, 039
5	Panel- Front	42"	330253301	1	
	Panel- Front	50"	330267301		1
6	Panel- Rear Door	42"	330253501	1	
	Panel- Rear Door	50"	330267401		1
10	Gasket		070199201	4 ft.	4 ft.

Control Panel
Main Control Box

Control Box Serial Number
"S" + Year + ##### + detail#

Control Box Part Number

BENSHAW
Serial: S2006001007 -1
McQuay P.O.: 606257
McQuay Part No.: 790993010B1R01
Box-Elec: K25_ACZ_016A_S_C_FAN_208_SDS_SSC_N_N_N
McQuay Ref. No.: 330620152
Benshaw Part No.: M183AGZ330620152
VOLTS FLA FREQ PHASE NEMA TYPE UL TYPE
208 60 50/60 3 3R 1
"Industrial Control Panel for Air Conditioning Equipment"

NOTE: For all control components, not listed below, please contact Daikin Applied with the **Control Box Serial Number** and **Control Box Part Number**. These numbers are located on the Control Box rating label (see example to the left). This label is found inside the panel.

Misc. Controls
Transducers, Pressure Switches and Sensors

Layout



Control Box Detail



Transducer Cable Detail

Ref No.	Sch. Sym.	Part Description	Part Number	Qty.
1		Controller must be programmed before shipping	330268111	1
2		Converter Board- Transducer	071857702	1
		Terminal Block- Converter Board 3 Pole	049759001	2
6		Tranducer Cable	350316651	2
6A		Boot- Transducer	071583301	2
6B		Pressure Connector- Transducer	074609001	2
	SC11	Pressure Control- Speedtrol	048445202	1
	C11	Capacitor- Speedtrol	037516428	1
	C BOX HEATER	Control Box Heater	330272001	1
	PVM	Phase Voltage Monitor 208/230V	070269963	1
		Phase Voltage Monitor 460V	070269965	1
		Phase Voltage Monitor 575V	070269966	1
N/S	S01	Transducer- Low Pressure 132 psi	071568501	1
N/S	S03	Transducer- High Pressure 400 psi	071568601	1
N/S	S00	Sensor- Leaving Water 10K, 10'	073007301	1
N/S	S05	Sensor- Outside Air 10K, 10'	073007301	1
N/S	HP1	Switch- High Pressure Open 400/Close 300 psi	073074002	1

N/S= Not Shown on Diagram.

Field Installed Accessories

Alarm Bell Kit

Ref. No.	Description	Part Number	Qty.
	Complete Kit	058090102	1
N/S	Alarm Bell Only	017809400	1
N/S	Relay	072937402	1

N/S= Not Shown on Diagram.

Phase Voltage Monitor Kit

Ref. No.	Description	Part Number	Qty.
	208/230V PVM Kit	350327801	
N/S	Phase Voltage Monitor only	070269963	1
	460V PVM Kit	350327901	
N/S	Phase Voltage Monitor only	070269965	1
	575V PVM Kit	350328001	
N/S	Phase Voltage Monitor only	070269966	1

N/S= Not Shown on Diagram.

Speedtrol Kit

Ref. No.	Description	Part Number	Qty.
	Complete Kit- 208/230/460V	350327601	
	Complete Kit- 575V	350327701 [1]	
N/S	Motor 208/230V	350113901	1
N/S	Fan Propeller	330288001	1
N/S	Capacitor 25MFD/440V	037516428	1
N/S	Heater- Control Box	330272001	1
N/S	Pressure Control	048445202	1

N/S= Not Shown on Diagram.
[1] Also includes a 575V Kit p/n 330315001 which includes transformer, fusing, and contactor.

Refrigerant Specialties

Description	Sizes	Kit p/n	Expansion Valve	Solenoid Valve	Filter Drier	Sight Glass
Specialies Kit	010, 013	350328701	072195005	025327500	025938900	330508601
Specialies Kit	016	350328801	072195004	025327500	025938900	330508601
Specialies Kit	020,025,028	350328901	072195002	025327500	025938900	330508601
Specialies Kit	033,039	350329001	072195003	025327500	025938900	330508601

Field Installed Accessories

Isolators— Rubber-In-Shear



Description	Sizes	Kit p/n	Individual Isolators			
			M1	M2	M3	M4
R-I-S Kit	010,013,016,020,025,028	350014859	021639701	021639701	021639704	021639704
R-I-S Kit	033, 039	350014857	021639703	021639703	021639701	021639701

Color Codes: 021639701= Red; 021639703= Green; 021639704= Black.

Isolators— Springs



To identify Spring Isolators, contact Daikin Applied with the Unit Model, Serial Number and GO/SO Number.

Field Installed Accessories



BACnet with IP/Ethernet

Ref. No.	Description	Part Number	Qty.
	BACnet IP/Ethernet Kit	350147406	
650	BACnet IP/Ethernet Interface Board	330358701	1



BACnet Communications Module MS/TP

Ref. No.	Description	Part Number	Qty.
	BACnet MS/TP Kit	350147404	
700	RS 232 Serial Interface Card Only	330343102	1
N/S	BACnet Communications Module Kit [1]	330274201	1
	Module Only	330274203	1
N/S	Connector- Wago 3 Pin	330803003	1
N/S	Tool- Wago Connector	330803050	1

N/S= Not Shown on Diagram.
[1] Includes module, communication cable and power wire.



MODBUS Communications Module

Ref. No.	Description	Part Number	Qty.
	MODBUS Installation Kit	350147402	
827	MODBUS Communications Module Only	330343101	1



LonMark Communications Module

Ref. No.	Description	Part Number	Qty.
	LonMark Installation Kit	350147401	
920	LonMark Communications Module Only	330343401	1

Critical Daikin Applied OEM Parts Are What Your Daikin Applied HVAC Unit Needs!

Air-Cooled Global Condensing Unit

ACZ

Sizes 010, 013, 016, 020, 025, 028, 033, 039 - Single Circuit

Vintage A

CRITICAL COMPONENTS	UNIT SIZE	VOLTAGE	PART NUMBER
CONTROLS			
Control Board	ALL	N/A	330268111
Transducer- Low Pressure	ALL	N/A	071568501
Transducer- High Pressure	ALL	N/A	071568601
Switch- High Pressure	ALL	N/A	073074002
TANDEM COMPRESSORS- R22			
Compressor 1 & 2, R22	010	208-230/60/3	331343301
Compressor 1 & 2, R22	013	208-230/60/3	074510101
Compressor 1 & 2, R22	016	208-230/60/3	074510201
Compressor 1 & 2, R22	020	208-230/60/3	074510301
Compressor 1 & 2, R22	025	208-230/60/3	074624001
Compressor 1 & 2, R22	028	208-230/60/3	074549101
Compressor 1 & 2, R22	033	208-230/60/3	074549201
Compressor 1 & 2, R22	039	208-230/60/3	330388401
Compressor 1 & 2, R22	010	460/60/3	331343302
Compressor 1 & 2, R22	013	460/60/3	074510102
Compressor 1 & 2, R22	016	460/60/3	074510202
Compressor 1 & 2, R22	020	460/60/3	074510302
Compressor 1 & 2, R22	025	460/60/3	074624002
Compressor 1 & 2, R22	028	460/60/3	074549102
Compressor 1 & 2, R22	033	460/60/3	074549202
Compressor 1 & 2, R22	039	460/60/3	330388402
Compressor 1 & 2, R22	010	575/60/3	331343302
Compressor 1 & 2, R22	013	575/60/3	074510103
Compressor 1 & 2, R22	016	575/60/3	074510203
Compressor 1 & 2, R22	020	575/60/3	074510303
Compressor 1 & 2, R22	025	575/60/3	074624003
Compressor 1 & 2, R22	028	575/60/3	074549103
Compressor 1 & 2, R22	033	575/60/3	074549203
Compressor 1 & 2, R22	039	575/60/3	330388403

Call Your Local Daikin Applied Parts Distributor For All Your Parts Needs.
To Locate A Distributor, Go To www.DaikinApplied.com or Call 1-800-37PARTS

Critical Daikin Applied OEM Parts Are What Your Daikin Applied HVAC Unit Needs!

Air-Cooled Global Condensing Unit

ACZ

Sizes 010, 013, 016, 020, 025, 028, 033, 039 - Single Circuit

Vintage A

CRITICAL COMPONENTS	UNIT SIZE	VOLTAGE	PART NUMBER
TANDEM COMPRESSORS - R407C			
Compressor 1 & 2, R407C	010	208-230/60/3	331507201
Compressor 1 & 2, R407C	013	208-230/60/3	331507301
Compressor 1 & 2, R407C	016	208-230/60/3	330662101
Compressor 1 & 2, R407C	020	208-230/60/3	330662201
Compressor 1 & 2, R407C	025	208-230/60/3	330663101
Compressor 1 & 2, R407C	028	208-230/60/3	330662401
Compressor 1 & 2, R407C	033	208-230/60/3	330662501
Compressor 1 & 2, R407C	039	208-230/60/3	330662601
Compressor 1 & 2, R407C	010	460/60/3	331507202
Compressor 1 & 2, R407C	013	460/60/3	331507302
Compressor 1 & 2, R407C	016	460/60/3	330662102
Compressor 1 & 2, R407C	020	460/60/3	330662202
Compressor 1 & 2, R407C	025	460/60/3	330663102
Compressor 1 & 2, R407C	028	460/60/3	330662402
Compressor 1 & 2, R407C	033	460/60/3	330662502
Compressor 1 & 2, R407C	039	460/60/3	330662602
Compressor 1 & 2, R407C	010	575/60/3	331507203
Compressor 1 & 2, R407C	013	575/60/3	331507303
Compressor 1 & 2, R407C	016	575/60/3	330662103
Compressor 1 & 2, R407C	020	575/60/3	330662203
Compressor 1 & 2, R407C	025	575/60/3	330663103
Compressor 1 & 2, R407C	028	575/60/3	330662403
Compressor 1 & 2, R407C	033	575/60/3	330662503
Compressor 1 & 2, R407C	039	575/60/3	330662603
CONDENSER FAN SECTION			
Fan Motor, Standard, 1.0HP, TE	010-020	208/230 & 460	330287901
Fan Motor, Standard, 1.0HP, TE	010-020	575	074521101
Fan Motor, Standard, 1.0HP, TE	025-039	208/230 & 460	330287901
Fan Motor, Standard, 1.0HP, TE	025-039	575	074521101
Fan Motor, SpeedTrol, 1.0HP, DP	025-039	All	350113901
Fan Prop, 26"	All	All	330288001

Call Your Local Daikin Applied Parts Distributor For All Your Parts Needs.
To Locate A Distributor, Go To www.DaikinApplied.com or Call 1-800-37PARTS